



PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

जिला जल जांच प्रयोगशाला
लोक स्वा० प्रमंडल, औरंगाबाद
निर्गत सं०...५१.....
तिथि...२५/०२/२०२५

It is certified that an inspection team headed by **Md Shami Akhatar Executive Engineer.**

(Name of Officer with designation) from...**PHED PH Division Aurangabad** (Name of Department/Office) inspected the **G.D Goenka Public School , Aurangabad.**

(Name and Address of the School) on **20.02.2025** (Date of Inspection) and found that the **G.D Goenka Public School , Aurangabad.** (Name of School) has safe drinking water facilities for the student and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of **Six months.**

All tested parameters are in permissible range.

Shafiq
22.02.25

Chemist
P.H. Div. Aurangabad

Chemist
P.H Division
Aurangabad

[Signature]
Assistant Engineer
P.H. Div. Aurangabad
Technical Manager
Com
Assistant Engineer:
P.H. Division, Aurangabad

Signature with Seal:
Name :
Designation :
Name & Address of the office/ Department:

To

G.D Goenka Public School
Sri Krishna vihar, Bijauli Road,
Aurangabad.

[Signature]
Quality Manager
Cum
Executive Engineer
P.H Division, Aurangabad.



Government of Bihar
District Level Water Testing Laboratory
P.H. Division, Aurangabad

जिला जल जाँच प्रयोगशाला
लोक स्वास्थ्य विभाग, औरंगाबाद
निर्गत सं०.....५०.....
दिथि.....२५/२/२०२५

District Name:- Aurangabad

Sample sent to Lab by :- Self

Sample Submitted in Lab on date :- 20-02-2025

S. N.	Block	Panchayat	Location of source	Chemical Parameters												
				p.H	Tur	EC	TDS	TH	Ca	Mg	ALk	Cl	Fe	SO ₄	F	T. Coli.
1	Dev	Kharkani	G.D.Goenka Public School Aurangabad	7.34	0.28	814	528	246	49.06	29.64	478	28.99	0.32	38	0.97	-VE
Acceptable Limit (IS 10500:2012)				6.50	1	-	500mg/l	200mg/l	75mg/l	30mg/l	200mg/l	250mg/l	1 mg/l	200mg/l	1.0mg/l	<1.1
Maximum Permissible Limit in absence of alternate source				8.50	5 NTU	-	2000mg/l	600mg/l	200mg/l	100mg/l	600mg/l	1000mg/l	NR	400mg/l	1.5mg/l	NR
Remarks:- All Parameters are in permissible range.																

G.D.Goenka Public School के द्वारा कार्यपालक अभियंता को जल नमूना जाँच हेतु 600 रुपये का Demand Draft दिनांक 06.02.2025 संख्या 014890 प्राप्त हुआ है।

Shailendra
22.02.25

Chemist

P.H. Division Aurangabad

Chemist
P.H Division
Aurangabad

22/02/2025

Assistant Engineer

P.H. Division Aurangabad

Technical Manager
Com
Assistant Engineer
P.H. Division, Aurangabad

22/02/25

Executive Engineer

P.H. Division Aurangabad

Quality Manager
Cum
Executive Engineer
P.H Division, Aurangabad